



Carrie Eklund
Central Services Manager
Finance Department

**ADDENDUM TO
WELL SITE DEMOLITION
At Unit Wells U28 And U24**

Bid No. 612-W-070

ADDENDUM NO.: 1

To: All Bidders:

Please make the following changes to the above mentioned bid package.

See attached.

All other portions remained unchanged.

A copy of this addendum or a reference thereto must be included with your bid or the bid will not be read or considered.

If you have any questions please contact the Central Services Division at (815) 987-5560.

DATED: July 11, 2012

FINANCE AND PERSONNEL COMMITTEE

Carrie Eklund
Central Services Manager

ADDENDUM #1

CITY OF ROCKFORD, Illinois

WATER FACILITIES IMPROVEMENTS WELL SITE DEMOLITION At Unit Wells U28 & U24

Owner Bid No. 612-W-070
McM. No. R0018-920370

Bid Date: Wednesday - July 25, 2012
Bid Time: 11:00 a.m., local time

This Addendum forms a part of the contract documents and modifies the original contract documents, dated June 25, 2012. The CONTRACTOR shall acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to acknowledge this Addendum will subject the bidder to disqualification.

GENERAL

Item #1 For the Bidder's Information, the address of U24 is 'Cessna Drive' (located at the south end of the Airport); and the address of U28 is '5400 Beltline Road' (located just north of the Airport).

SPECIFICATIONS

Item 1 DIVISION 2 - SITE WORK

- A. Section 020500 - Site Structure Demolition:
1. Paragraph 1.02.C: DELETE this paragraph in its entirety, and REPLACE with the following:
 - "C. The CONTRACTOR shall carefully remove four (4) 8" x 8" tee sections, four (4) 8-inch butterfly valves, and three (3) 6-inch butterfly valves from the face piping at U24 or U28 (as directed by the OWNER). These valves and fittings shall be carefully set aside for the OWNER to salvage and reuse. The CONTRACTOR will not be required to deliver a vessel to the City of Rockford Fire Department."

DRAWINGS

Drawing C1

- A. DELETE General Note #3, which describes delivery of one of the carbon vessels to the City of Rockford Fire Department. This delivery will not be required. All vessels will become the property of the CONTRACTOR.

Issued: July 12, 2012

MCMAHON

STREET: 1445 MCMAHON DRIVE, NEENAH, WI 54956
MAILING: P.O. BOX 1025, NEENAH, WI 54957-1025
TELEPHONE: 920.751.4200
FAX: 920.751.4284

W:\WP\SPEC\R0018\920370\Addendum-1.docx

ADDENDUM #1
CITY OF ROCKFORD, ILLINOIS
WATER FACILITIES IMPROVEMENTS | WELL SITE DEMOLITION At Unit Wells U28 & U24
Owner's Contract No. 612-W-070 / McM. No. R0018-920370